MISSISSIPPI STATE DEPARTMENT OF HEALTH BUREAU OF PUBLIC WATER SUPPLY CCR CERTIFICATION CALENDAR YEAR 2013 Town of Mayersville

*OWN OI MAYELBVIILE
Public Water Supply Name
- Try
0280001
List PWS ID #s for all Community Water Systems included in this CCR

The Federal Safe Drinking Water Act (SDWA) requires each Community public water system to develop and distribute a Consumer Confidence Report (CCR) to its customers each year. Depending on the population served by the public water system, this CCR must be mailed or delivered to the customers, published in a newspaper of local circulation, or provided to the customers upon request. Make sure you follow the proper procedures when distributing the CCR. You must mail, fax or email a copy of the CCR and Certification to MSDH. Please check all boxes that apply.

emad a copy of the CCN and Certification to MASDIA. I asis	E LIEUR ME VOLES MUE Apply.
Customers were informed of availability of CCR by	: (Attach copy of publication, water bill or other)
Advertisement in local paper (atta On water bills (attach copy of bill) Email message (MUST Email the Other	ch copy of advertisement)) message to the address below)
Date(s) customers were informed:/,	
CCR was distributed by U.S. Postal Service or methods used US Postal Service - M	other direct delivery. Must specify other direct delivery ailed with water bills.
Date Mailed/Distributed: 07 / 01/2014	
CCR was distributed by Email (MUST Email MSD As a URL (Provide URL As an attachment	OH a copy) Date Emailed: / /
As text within the body of the ema	iil message
CCR was published in local newspaper. (Attach cop	y of published CCR or proof of publication)
Name of Newspaper:	
Date Published: / /	
CCR was posted in public places. (Attach list of loc	ations) Date Posted: / /
CCR was posted on a publicly accessible internet sit	e at the following address (DIRECT URL REQUIRED):
1	
the SDWA. I further certify that the information include	eport (CCR) has been distributed to the customers of this above and that I used distribution methods allowed by led in this CCR is true and correct and is consistent with public water system officials by the Mississippi State
and the supply of the supply o	
Name Title (President, Mayor, Owner, etc.)	07/01/2014 Date
traing that (treatment, water, Christer, Ett.)	<i>Dute</i>
Deliver or send via U.S. Postal Service:	May be faxed to:

Bureau of Public Water Supply P.O. Box 1700 Jackson, MS 39215

(601)576-7800

May be emailed to: Melanie. Yanklowski@msdh.state.ms.us

2013 Annual Drinking Water Quality Report Town of Mayersville PWS ID #: 0280001 May 2014

We're pleased to present to you this year's Annual Quality Water Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water source is from three walls drawing from the Sparta Sand Aquifer.

The source water assessment has been completed for our public water system to determine the overall ausceptibility of its drinking water supply to identify potential sources of contamination. A report containing detailed information on how the susceptibility determinations were made has been furnished to our public water system and is available for viewing upon request. The wells for the Town of Mayersville have received a lower susceptibility ranking to contemination.

If you have any questions about this report or concerning your water utility, please contact Mayor Linda W. Short at 662.873.6439. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled maetings. They are held on the first Wednesday of each month at 5:00 PM at the Mayoraville Multi Purpose Building.

We routinely monitor for constituents in your drinking water according to Federal and State laws. This table below lists all of the drinking water contaminants that we detected during for the period of January 1st to December 31st, 2013. In cases where monitoring wasn't required in 2013, the table reflects the most recent results. As water travels over the surface of tand or underground, it dissolves naturally occurring minerals and, in some cases, radioactive materials and can pick up substances or contaminants from the presence of animals or from human activity; microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plents, septio systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm-water runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming; posticides and herbicides, which may come from a variety of sources such as agriculture, urban storm-water runoff, and residential uses; organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations and septic systems; radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some constituents. It's important to remember that the presence of these constituents does not necessarily indicate that the water poses a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand those terms we've provided the following definitions:

Action Level - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Treatment Technique (TT) - A treatment technique is a required process intended to reduce the level of a contaminant in drinking water.

Maximum Contaminant Level (MCL) - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best evailable treatment technology.

Maximum Contaminant Level Goal (MCLG) - The "Goal" (MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL) — The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary to control microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG) – The level of a drinking water disinfectant below which there is no known or expected risk of health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

	-			TEST RES	ULTS			
Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measure- ment	MCLG	MCL	Likely Source of Contamination
Inorganic	Contam	inants						
10. Barlum	N	2012*	.014	No Range	ppm	2	2	Discharge of drilling wastes: discharge from metal refineries; erozion of natural deposits
13. Chromium	N	2012*	2	78 – 2	ppb	100	100	Discharge from atoel and pulp mills: erosion of natural deposits
14. Copper	N ">	2009/11*	.2	0	ppm	1.3	AL=1.3	Corresion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives

16. Fluoride	N	2012*	.55	No Range	ppm		4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
17. Lead	N	2009/11	2	0	dqq		O AI	=16	Corrosion of household plumbing systems, ercelon of natural deposits
Disinfection									
81. HAA5	N	3Q2013	S 43 RAA	11 - 77	ррв	٥١	60		-Product of drinking water Infection.
				11 - 77 7.46 - 64	dqq	0	60	By	

Most recent sample. No sample required for 2013.

Disinfection By-Products:

(81) Haloacetic Acids (HAA5). Some people who drink water containing bromate in excess of the MCL over many years may have an increased risk of cancer (82) Total Trihalomethanes (TTHMs). Some people who drink water containing trihalomethanes in excess of the MCL over many years may experience problems with their liver, kidneys, or central nervous systems, and may have an increased risk of getting cancer.

As you can see by the teble, our system had no violations. We're proud that your drinking water meets or exceeds all Federal and State requirements. We have learned through our monitoring and testing that some constituents have been detected however the EPA has determined that your water IS SAFE at these levels.

We are required to monitor your drinking water for specific constituents on a monthly basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. In an effort to ensure systems complete all monitoring requirements, MSDH now notifies systems of any missing eamples prior to the end of the compliance period.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Our Water Association is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at http://www.epa.gov/safewater/lead. The Mississippi State Department of Health Public Health Laboratory offers lead testing. Please contact 601.576.7582 if you wish to have your water tested.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

Some people may be more vulnerable to contaminante in drinking water than the general population. Immuno-compromised persons auch as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infactions. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Holline 1-800-426-4791.

We at the Town of Mayersville work around the clock to provide top quality water to every tap. We ask that all our customers help us project our water sources, which are the heart of our community, our way of life and our children's future.